



Certificate number: 2311727 (1)

Issued 08/11/2023

Expires 08/11/2028

## Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

### Dutypoint Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

# CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate Issued to:**  
Dutypoint Ltd  
2 Olympus Park Quedgeley  
Gloucester  
GL2 4DH



**KUKreg4**

# Product Certificate

Appendix to Certificate number: 2311727

The following products belong to this certificate

<p><b>PRODUCT DESCRIPTION</b> AirBREAK Cat 5 Pump Set with single/twin variable speed pumps and 90L/36L fixed speed pumps. ATS3 – Without Production Surveillance.</p>
<p><b>MODEL(S)</b> VQ1 VQ2 FQ1** FC1</p> <p>Example of Model Number: VQ1-05-015M Range: VQ (other options are FQ &amp; FC) Number of Pumps: 1 Nominal Flow: 05 (m3hr) Motor kw (without decimal): 015 (1.5kw) Voltage: M (T=400/3/50 M=230/1/50)</p> <p>*Where 16 Bar outlet pressure is required, the only component changed is the pressure vessel. ** the only difference between VQ1 and FQ1 is the electrical control type, so the VQ1 sample will also serve as the FQ1 sample</p>
<p><b>SIZE:</b> ½" BSP (F) 1" BSP (F) 1 ¼" BSP (F)</p>
<p><b>SCOPE:</b> Manufacturer recommended maximum working pressure 10 Bar &amp; maximum operating temperature: Cold water use only. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only.</p>
<p><b>MARKING</b> Dutypoint, Address, Model, Serial No and pressure rating on adhesive label on panel.</p>
<p><b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p><b>BACKFLOW PROTECTION NOTES</b> N/A.</p>
<p><b>ADDITIONAL NOTES</b> All water contact &amp; exposed components satisfy opacity requirements.</p>

## Extra Notes